


# ELECTRICAL SAFETY RECALL

## Infinity Electrical Cable

All Infinity TPS cable and Infinity Orange Circular



### IDENTIFICATION:

The ACCC has requested recall of ALL Infinity TPS cable and Orange Circular Cable. All cables are branded with the word 'Infinity' and were supplied between April 2012 to August 2013.

### HAZARD:

Over time, the PVC sheathing may become brittle when exposed to high temperatures reducing the cable insulation integrity. There is potential to cause fire or a serious electrical shock.

### ACTION REQUIRED:

Do not use cable. Discontinue use immediately and return product to place of purchase for a full refund or replacement.

### For further information

Please direct all calls and any queries concerning this recall to  
Network Electrical Supplies on 02 9679 2886 or [sales@networkelectricalsupplies.com.au](mailto:sales@networkelectricalsupplies.com.au)

See [www.recalls.gov.au](http://www.recalls.gov.au) for Australian product recall information